



Product Service

# CERTIFICATE

No. B 17 03 13890 02811

**Holder of Certificate:** **Astec International Ltd.**  
 16th Floor, Lu Plaza, 2 Wing Yip Street  
 Kwun Tong  
 Kowloon  
 HONG KONG



**Certification Mark:**



**Product:** **Converter  
 (DC-DC Converter)**

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

**Test report no.:** 682301707001

**Valid until:** 2019-06-19

**Date,** 2017-03-16  
 Page 1 of 2

*(Signature)*  
 (Yager Bi)





**CERTIFICATE**

**No. B 17 03 13890 02811**

**Model(s): ADQ800-48S12XXXXXXXXXX**  
**(X may be represented by any ASCII character code, no safety impact)**

**Parameters:**

Rated Input :	40-60VDC, 23A Max.
Rated Output :	11.6VDC, 70A
Protection Class :	Built-in component, consider in end system
Degree of Protection :	IPX0
Remarks:	

- When installing the equipment, all requirements of the mentioned standard must be fulfilled.
- Basic insulation is provided between the input circuit and output circuit / base plate.
- Clearance was evaluated for operating altitude up to 3000m above sea level.
- The built-in converter shall be connected to a source which is insulated from the mains supply by min. reinforced insulation.
- The built-in converter has no in-line fuse, for safety operation, an external 30A, 125VDC fuse for models ADQ800-48S12XXXXXXXXXX must be employed as input line before installation.
- Maximum operating ambient temperature of model ADQ800-48S12XXXXXXXXXX is 25°C with full loading & air velocity 2.0m/s, cooling control method: from Vin- to Vin+.
- The secondary output is energy hazard (>240VA). When installing into end system, care shall be taken that the output and the appropriate wire may not be touched.

**Tested according to:** EN 60950-1:2006/A2:2013

**Production Facility(ies):** 41329, 26247